

FIRE SAFETY CERTIFICATE


No. 76/2024

Date : 04/10/2024

Certified that the **L. H. Patil English Medium School** at Gat No.116/1/1, Wawadade, Tal. & Dist. Jalgaon (MH) Comprised of Ground Floor + 1st Floor + 2nd Floor Owned / Occupied By **L. H. Patil English Medium School** have Compiled with the Fire Prevention & Fire Safety Requirements in Accordance With Rule Of Maharashtra Fire Prevention & Life Safety Act 2006 (Mah.III of 2007) Rules & Verified By The Officers Concerned of Fire Service On 3 October 2024 in the Presence of **Mrs. Jayashri Muralidhar Patil, Principle, L. H. Patil English Medium School** at Gat No.116/1/1, Wawadade, Tal. & Dist. Jalgaon (MH) & that the Building / Premises is Fit for Occupancy Up to **XIIth** With Effect From 7 June 2024 For Period of **One Year** In Accordance With Rule & Subject to Compliance of specific conditions as appended.

Issued On 4 October 2024 at Fire Dept. Of Malegaon (Dist. Nasik) by the undersigned.




(Pawar S. D.)

Chief Fire Officer

Malegaon Municipal Corporation


To,
The Principle
L. H. Patil English Medium School
Gat No.116/1/1, Wawadade
Tal. & Dist. Jalgaon

ENDORSEMENT

THE NO OBJECTION CERTIFICATE ISSUED BY FIRE SERVICE STAND CANCELLED AN ANNULLED DUE TO.


NIL




(Pawar S. D.)

Chief Fire Officer

Malegaon Municipal Corporation

Sr. No.	Year	Period (B Form)	Sign & Seal
1	07/06/2024 to 06/06/2025	Jan. to June	 Chief Fire Officer Malegaon Municipal Corporation



All Types Of Fire Protection Equipments Sales & Services, Supplier & Stockist Industrial Safety Appliances

Date – 06/06/2025

Ref – RFS /25-26/222

CERTIFICATE

This is to certify that **L. H. PATIL ENGLISH MEDIUM SCHOOL**. Has Refilled, reconditioned, leakage check, Discharge & H.P tested as per and conforming to I.S 2190:2010 (Selection, installation and maintenance of first – aid fire extinguisher). The details of work done for fire extinguisher are as follows.

Sr. No	Type of Fire Extinguisher	Capacity	Nos
1	ABC TYPE FIRE EXTINGUISHER	5 KG	3 NOS
2	ABC TYPE FIRE EXTINGUISHER	4 KG	2 NOS
3	ABC TYPE FIRE EXTINGUISHER	9 KG	1 NOS
4	ABC TYPE FIRE EXTINGUISHER	2 KG	5 NOS
5	ABC TYPE FIRE EXTINGUISHER	1 KG	6 NOS
6	DCP TYPE FIRE EXTINGUISHER	5 KG	3 NOS
7	CO2 TYPE FIRE EXTINGUISHER	4.5 KG	1 NOS

Refilling Date – 06/06/2025

Next due date – 05/06/2026

Place – Jalgaon

Date – 06/06/2025



Signature and stamp of agency