

PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

डा.क/सामय्याला/११/१५/२०२४
डा.का.के. देवदास ला.मि. लवदादे
Date : 24/09/2024

CERTIFICATE. No. _____

It is certified that an inspection team headed by Mr. Anil Mahojra (M.P.H.)

(Name of Officers with designation) from **Medical Officer, Primary Health Center, Mhasawad, Tal. And**

Dist. Jalgaon, MS. (Name of Department/Office) inspected the **School. L. H. Patil English Medium**

School, Gat No. 116/1/1, Wawadade, Tal. And Dist. Jalgaon. MS. (Name & Address of the School) on


and found that the **L. H. Patil English Medium School** (Name of school) has safe drinking water

facilities for the students and members of staff of the institution and is maintaining the hygienic

sanitation condition in the school building & the campus as per the norms prescribed by the

Central/State/U.T Govt.

The above valid for a period of October-2024 to September 2025.

Signature with Seal : 

Name : Dr. N.P. Ayrovel

Designation : Medical Officer

To .

The Principal,

L. H. Patil English Medium School, Gat No. 116/1/1, Wawadade,

Tal. And Dist. Jalgaon. MS. (Name & Address of the Institution)

Medical Officer
Primary Health Centre
Mhasawad Tal. Dist. Jalgaon



Since 1994

SHREE ATR LABORATORY

SERVICES (OPC) PRIVATE LIMITED

- NABL Accredited Testing Laboratory Vide Certificate No : TC-10630
- Government of Maharashtra Approved Soil & Water Test Lab

Testing of Water | Foods | Drinks | Herbals | Soil | Chemicals | Fertilisers | Metals | Plastic
NABL Accredited laboratory TC-14380

1.	Test Reports No: Date of Issue	SATRL/24-25/11/002 20/12/24.
2.	Name & Address of the Customer	L.H Patil English Medium School Wavadada Tal- Dist- Jalgaon
3	Sample Name	Drinking water .
4	Date of Sample Receipt : Date of Reporting Lab Id : Sample Submitted by	15/12/24 20/ 12/ 2024 SATRL/24-25/11/002 Customer

Chemical Test: -

TEST RESULTS

Sr. No.	Test Parameters	Results	Requirement As per IS 10500 Specification	Test Method
1	Taste	Acceptable	Should be acceptable	IS 3025(P-11)1983
2	Odour	Acceptable	Should be acceptable	IS 3025(P-5)1984
3	Colour	< 1.00	< 2.0 hazen unit	IS 3025(P-4)1984
4	pH Value	6.90	6.50-8.50	IS 3025(P-11)1983
5	Electrical Conductivity	0.120	-----	IS 3025(P-14)1984
6	Total Dissolved Solids	80.	500 mg/lit	IS 3025(P-16)1984
7	Chlorides, as Cl	1.30	250 mg/lit	IS 3025(P-32)1983
8	Calcium, as Ca	0.50	75 mg/lit	IS 3025(P-40)1984
9	Magnesium, as Mg	0.10	30 mg/lit	IS 3025(P-46)1984
10	Total Hardness, as CaCO ₃	20.8	200 mg/lit	IS 3025(P-21)1984
11	Total Alkalinity,	15.0	200 mg/lit	IS 3025(P-17)1984
12	Iron, as Fe	0.005	0.30 mg/lit	IS 3025(P-53)1984
13	Nitrate, as NO ₃	3.10	45 mg/lit	IS 3025(P-34)1984
14	Sulphate, as SO ₄	0.10	200 mg/lit	IS 3025(P-24)1983
15	Fluoride, as F	0.05	1.0 mg/lit	IS 3025(P-60)1984
Microbiological Testing				
16	Total coliform bacteria cfu/ ml	Absent	Absent in 100 ml	IS 15185:2016
17	E.coli cfu /ml	Absent	Absent in 100 ml	IS 15185:2016

Remark- Water is Potable in respect above said tested parameters

Verified by
(Sr Micro Analyst)

Reviewed & Authorized
(Technical Manager)

Shop 32-35, Sureshdada Jain Vegetable Market, Jalgaon-425003(M.S)

9370007446 | 7448174467 | 9503631793

test@shreeatrlabs.com | www.shreeatrlabs.com